



Gary Hinshaw
Fire Warden

Ray Jackson
Deputy Fire Warden

Ken Slamon
Fire Marshal

3705 Oakdale Road, Modesto, CA 95357
Phone: 209.552.3700 Fax: 209.552.2512

Fire Alarm and Sprinkler Monitoring

Listed below are the basic information requirements to complete a Stanislaus County Fire Prevention Bureau plan review.

Not all items may pertain to your project.

- 1. Submit a completed application along with three (3) copies of the floor plan to an indicated scale, on a minimum size sheet of 24" x 36" with \$110.00 non-refundable deposit for the 1st hour of plan check fees.
- 2. Indicate the scope of work for the project on the plans. List whether occupancy classification is A, R, E, B, or M. List maximum Occupancy Load on the plans.. Show all pull stations- Horn & Strobe panels, etc.
- 3. Indicate the project name, full street address, tract number of the project (tract number not needed for water monitoring), plan drawing or revision date and building permit number on the plans. If applicable, show the type of sprinkler system, NFPA 13, 13R, or 13D. Show the number of sprinkler heads.
- 4. Show battery calculation and voltage drop calculation on worksheets.
- 5. Show the sequence of operations.
- 6. Show point to point wiring.
- 7. Show legend for fire alarm components.
- 8. Show all current NFPA alarm notes **verbatim** on plans.
- 9. Provide three sets of data sheets for all fire alarm components to be installed.
- 10. Provide current California State Fire Marshal listing sheets for all devices and equipment.
- 11. Indicate central monitoring station's name, phone number, address and UL or FM number on the plans. Provide contact information - owner, tenant or occupant's information.
- 12. Provide the contractors or system designer's registration number, license class (C7 or C10) and expiration date on the plans.

Direct technical questions to 209 552-3700

Providing the above-listed information does not guarantee plan approval.