



FIRE ALARM AND SPRINKLER MONITORING

Listed below are the basic information requirements to complete a plan review.
Not all items may pertain to your project.

- 1. Submit pdf plans, calculations, material data sheets and application form to fireprevention@stancounty.com. Incomplete submittals will not be accepted.

***Once plans have been finalized and approved: submit two copies of noted and approved plans on a minimum sheet size of 24" x 36", to obtain the County stamp and signature. Until then a hard copy for plan check is not necessary or needed.
- 2. Indicate the project name, full street address, Assessors Parcel Number (APN), tract number, and associated building permit number. Show north pointing arrow.
- 3. Provide contractor's name, address, phone number, type of license (C7, C10 or C-16), license number, and date of expiration. All plans must be "wet" or electronically signed.
- 4. Note current California Building Code, California Fire Code, and NFPA references.
- 5. Include a comment whether or not a site plan is required and if it has it been approved.
- 6. Indicate property lines, nearby buildings, adjoining suites, driveways, and streets.
- 7. Describe the scope of work. Cloud or isolate project areas.
- 8. Show battery calculation and voltage drop calculation worksheets.
- 9. Show the matrix sequence of operations.
- 10. Show point-to-point wiring.
- 11. Show legend for fire alarm components.
- 12. Include all current NFPA 72 alarm notes (verbatim) on the plans.
- 13. Provide one set of manufacturer's cut sheets for all fire alarm components installed.
- 14. Provide current California State Fire Marshal listing sheets for all fire alarm components to be installed.
- 15. Indicate central monitoring station's name, phone number, address, and UL or FM number on the plans.
- 16. Provide UL certification number or a note that UL will be obtained prior to permit signoff. (California Fire Code)

Direct technical questions to Stanislaus County Fire Prevention Bureau at 209-552-3700.

Providing the above-listed information does not guarantee plan approval.